

Air-Cooled Engines


Model 006483-0
Model 006484-0



DESCRIPTION

Scheduled maintenance is a necessity for all standby generators. The Air Cooled Scheduled Maintenance kits offer all the components necessary to perform a complete maintenance on Generac air-cooled generators. Oil will need to be purchased separately based upon the recommendations listed. Maintenance is recommended at every 200 hours or 2 years. If running in a dusty environment, more frequent maintenance may be required. Maintenance intervals may differ per model. Refer to the generator owner's manual for more information.

OIL RECOMMENDATIONS



KIT CONTENTS

Kit Model	006483-0	006484-0	
	8 kVA (530cc)	10 kVA (992cc)	13 kVA (992cc)
Air Filter	•	•	•
Oil Filter	•	•	•
Spark Plug(s)	2	2	2
Oil Funnel	•	•	•
Chamois	•	•	•
Reminder Sticker	•	•	•

*Contents of kits may vary. The maintenance kits listed above are for models manufactured after April of 2013 equipped with the Evolution controller. For maintenance items for older models, please contact a dealer.